

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 6911-0694:257

Page 1 of 1

CATEGORY: Voice Communication Systems Control Units

LISTEE: Fire Control Instruments, *16 Southwest Park, Westwood MA 02090
Contact: Anthony J. Shalna (781) 471-3000 FAX (781) 471-3099

DESIGN: Model NetSOLO Broadband Voice Evacuation System. The unit is a multi-channel voice evacuation/emergency message panel. The unit is intended to be used in conjunction with the listed 7100 series Control Panel (CSFM Listing No. 7165-0694:219). Refer to listee's data sheet for detailed product description and operational considerations. System components:

7100 Series	Fire Alarm Control Panel
INI-CC	Central Command & Control Center
INX	Network Audio Transponder

RATING: 120 V, 60 Hz, 3.5 A

INSTALLATION: In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a voice evacuation system for use with a separately listed electrically compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details

NOTE: If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal.

*Rev. 02-05-2004KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**